



APPROVALS®

Certificate of Conformity

Certificate No.: SAA-181998-EA

Certificate Holder: Suntree Electric Co., Ltd.
No.3 Siqian Road,
Xinguang Industrial Zone,
LiuShi Town, YueQing,
Zhejiang,
P.R. China

Class Description: DC Isolator
Product Description: PV Switch-Disconnecter

Brand Name:



Model No.:

SISO-40

Markings:

1200Vdc /4P 16A

IP66NW, DC-PV2

Standard:

AS 60947.3:2018

AS/NZS IEC 60947.1:2015

Conditions:

Nil

Approval Mark:

RCM and SAA-181998-EA

Date First Registered:

27 July 2018

Date of Expiry:

27 July 2023

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Old Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 27-07-18 181998/1

www.jas-anz.org/register



APPROVALS®

Certificate of Conformity

Addendum

Certificate No.: SAA-181998-EA

Date of Issue: 27 July 2018

Class Description: DC Isolator

Product Description: PV Switch-Disconnecter

General Modification:

Use of alternative trade name



For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Old Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 27-07-18 181998/2

www.jas-anz.org/register



APPROVALS®

Certificate of Approval

Addendum

Certificate No.: SAA-181998-EA

Date of Issue: 12 September 2018

Class Description: DC Isolator

Product Description: PV Switch-Disconnecter

General Modification:

Change of temperature range from (-25°C to +85°C) to (-40°C to +85°C).

Use of additional ratings

1200Vdc (Ie=10, 32A), 1000Vdc (Ie= 16, 32A), 800Vdc (Ie=25, 40A), 600Vdc (Ie=40, 50A).

Additional Models

SISO-40MD

Description

Similar to SISO-40MD except rated IP20 and without external enclosure.


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 12-09-18 181998/3